



May 7, 2015

USG Corporation  
700 North Highway 45  
Libertyville, IL 60048

Subject: Evaluation of Coatings Coverages with Water Resistive Barriers/Primers on New Coated USG Securock® Glass-Mat Sheathing vs. GP DensGlass® Sheathings

To whom it may concern:

This letter is to confirm that samples of USG Securock® Glass-Mat Sheathing (new improved version with coated mat) and GP DensGlass® Sheathing were tested by Progressive Engineering, Inc. PEI Project No. 2014-1296 to compare coverage rates for each of the following products as measured by film thickness and visual observation or the coverage area:

**Air/Water Membranes**

1. Henry Air-Bloc 32MR Liquid Emulsion Air/Vapor Barrier Membrane
2. Grace Perm-A-Barrier® VP Vapor Permeable Air Barrier
3. Carlisle® Barriseal-R
4. Tremco ExoAir™ 120 SP
5. Tremco ExoAir® 230
6. Sto Gold Coat® 80265 Waterproof Fluid-Applied Membrane
7. StoGuard® VaporSeal™ 80263
8. Proscor Guard® CAT5®
9. DryVit - ADEPS adhesive

**Primers**

1. Henry Blueskin® Adhesive
2. Grace Perm-A-Barrier® WB Primer
3. Carlisle® CCW-702 Quick-Dry Contact Adhesive
4. Tremco ExoAir® Primer

**Flashing**

1. ExoAir® 111 Foil



*Progressive Engineering Inc.*

---

The USG Securock® Glass-Mat Sheathing and GP DensGlass® Gold Sheathings demonstrated comparable coverage rates as determined by this test program. Additionally, the primer coatings provided a similar surface adhesion based on the peel adhesion tests.

Please feel free to contact me with any questions or concerns at 574-533-0337 ext. 144 or via e-mail at [jholdeman@p-e-i.com](mailto:jholdeman@p-e-i.com).

Sincerely,

A handwritten signature in black ink, reading 'Jason R. Holdeman', is written over a horizontal line. The signature is positioned to the left of a large, faint, light gray version of the P-e-i logo that serves as a background watermark.

Jason R. Holdeman  
Director of Testing